



Florida Department of Environmental Protection

Marjory Stoneman Douglas Building
3900 Commonwealth Boulevard
Tallahassee, Florida 32399-3000

Rick Scott
Governor

Carlos Lopez-Cantera
Lt. Governor

Noah Valenstein
Secretary

October 18, 2017

NOTICE TO APPLICANTS ADDENDUM NO. ONE (1)

C.H. Corn Hydroelectric Generating Station DEP Bid NO. BDC11-17/18

TO BIDDERS AND PLAN HOLDERS ON THE ABOVE REFERENCED PROJECT: PLEASE NOTE CONTENTS HEREIN AND INCLUDE WITH YOUR BID SUBMISSION.

NOTICE

It will be required that this addendum be signed in acknowledgment of receipt and that it be included with your Bid when same is submitted to Mae Roth, Government Operations Consultant II, Bureau of Design and Construction, 3800 Commonwealth Blvd. MS520, Tallahassee, Florida 32399-3000. Failure to do so may be grounds for rejection of the Bid.

Signature of Contractor and Date

The Following statements supersede & supplement the corresponding items in the specifications & drawings:

The following clarifications are hereby incorporated into the bidding package:

- **The attached letter from Duke Energy**

In all other respects, the contract documents of which this is an Addendum, and attachments relative thereto, shall remain in full force and effect.



October 18, 2017

Florida Department of Environmental Protection – Bureau of Public Land Administration
3900 Commonwealth Boulevard
Tallahassee, Florida 32309-3000
Attn. Cheryl McCall

Sent via email: cheryl.mccall@dep.state.fl.us

Subject: Jackson Bluff Hydro Plant

Dear: Ms. McCall,

You had asked if I could send responses to your earlier questions in a letter format.

Questions;

- 1.) Is the transmission agreement that Duke Energy Florida has with the City of Tallahassee eligible for assignment.

Yes, by executing a SERVICE AGREEMENT FOR THE RESALE, REASSIGNMENT OR TRANSFER OF POINT-TO-POINT TRANSMISSION SERVICE that is Attachment A-1 to the Joint [OATT](#).

- 2.) What is the transmission capability of the City of Tallahassee transmission agreement that is eligible for assignment.

11 MW of capability is assignable.

- 3.) Does DEF want to have Jackson Bluff Hydro back for its own operation?

No.

- 4.) When the City is no longer the operator of the plant would the new operator be able to negotiate a new agreement?

Yes, pursuant to the procedure in the Joint [OATT](#) section 23.1.

Sincerely,

A handwritten signature in black ink that reads "Paul G. Graves".

Paul G. Graves
Lead System Operations Analyst
(727) 384-7519