



FLORIDA DEPARTMENT OF Environmental Protection

Marjory Stoneman Douglas Building
3900 Commonwealth Boulevard
Tallahassee, Florida 32399-3000

Rick Scott
Governor

Carlos Lopez-Cantera
Lt. Governor

Noah Valenstein
Secretary

March 26, 2019

NOTICE TO APPLICANTS ADDENDUM NO. ONE (2)

Oscar Scherer State Park – Bridge to Campground DEP Bid NO. BDC21-18/19

TO BIDDERS AND PLAN HOLDERS ON THE ABOVE REFERENCED PROJECT: PLEASE NOTE CONTENTS HEREIN AND INCLUDE WITH YOUR BID SUBMISSION.

NOTICE

It will be required that this addendum be signed in acknowledgment of receipt and that it be included with your Bid when same is submitted to Alyssa Skehan, Government Operations Consultant II, Bureau of Design and Construction, 3800 Commonwealth Blvd. MS520, Tallahassee, Florida 32399-3000. Failure to do so may be grounds for rejection of the Bid.

Signature of Contractor and Date

The Following statements supersede & supplement the corresponding items in the specifications & drawings:

- 1. Question:** Would rolled W shapes be acceptable in lieu of tubular members? Tubular members are difficult to galvanize and there is no guarantee that all surfaces inside tubes have proper galvanizing millage. W shapes allow for easier inspection and a more consistent galvanized coating.
Answer: The Engineer does not object to the use of w-shape instead of tubular members.
- 2. Question:** Could someone clarify loading. I see it calls for LRFD but what loading HL 93?
Answer: HL-93 is the live load to be used for design as per AASHTO LRFD.

In all other respects, the contract documents of which this is an Addendum, and attachments relative thereto, shall remain in full force and effect.