



**Florida Fish
and Wildlife
Conservation
Commission**

Commissioners
Robert A. Spottswood
Chairman
Key West

Michael W. Sole
Vice Chairman
Tequesta

Joshua Kellam
Palm Beach Gardens

Gary Lester
Oxford

Gary Nicklaus
Jupiter

Sonya Rood
St. Augustine

Office of the
Executive Director
Eric Sutton
Executive Director

Thomas H. Eason, Ph.D.
Assistant Executive Director

Jennifer Fitzwater
Chief of Staff

850-487-3796
850-921-5786 FAX

Finance and Budget Office
Kurt Fritsch
Finance & Budget

(850) 488-6551

*Managing fish and wildlife
resources for their long-term
well-being and the benefit
of people.*

620 South Meridian Street
Tallahassee, Florida
32399-1600
Voice: 850-488-4676

Hearing/speech-impaired:
800-955-8771 (T)
800 955-8770 (V)

MvFWC.com

DATE: SEPTEMBER 6, 2019

ADDENDUM NO.: 2

BID NO.: FWC 18/19-130C

BID TITLE: TENOROC ENTRY BUILDING AND SITE
IMPROVEMENTS

UPDATE: ITEM 1: ANSWERS TO WRITTEN QUESTIONS; ITEM 2:
UPDATE CONTACT FOR CONFIDENTIALITY EXEMPTION
FORM SUBMISSION

The enclosed addendum has been issued for consideration in the preparation of your response to the Florida Fish and Wildlife Conservation Commission's (FWC) Solicitation No. FWC 18/19-130C, "TENOROC ENTRY BUILDING AND SITE IMPROVEMENTS".

All responses to the subject solicitation must be received no later than 3:00 PM (ET) on Thursday, September 12, 2019.

A response received after the exact time specified will not be considered. Failure to file a protest within the time prescribed in Section 120.57(3), Florida Statutes (F.S.), or failure to post the bond or other security required by law within the time allowed for filing a bond shall constitute a waiver of proceedings under Chapter 120, Florida Statutes. Written notices, formal requests and proceedings must conform with the requirements set forth in Chapter 28-110, Florida Administrative Code (F.A.C.). Protests must be filed with the Purchasing Office, Fish and Wildlife Conservation Commission, 2590 Executive Center Circle, Suite 100, Tallahassee, Florida 32301 within the time prescribed in Section 120.57(3), F.S. and Chapter 28-110, F.A.C.

Sincerely,

Alyssa DeLong,

FWC Procurement Manager

BEGIN ADDENDUM

Item 1: Answers to Written Questions

QUESTION #1

SP 9.5. What is the Traffic Level of this Asphalt, and what is the percent of RAP (Recycled Asphalt Product) allowed in the mix?

ANSWER #1

The Superpave Traffic Level is B. The maximum RAP percent is 50% by weight. The asphalt binder shall be selected per Table 334-1 of the FDOT Standard Specifications for Road and Bridge Construction (July 2019).

QUESTION #2

In Pre-Bid meeting it was stated that all of the Drainage system was in place. Upon further inspection the MES were never installed. Are we to install the MES or leave them as is?

ANSWER #2

Contractor will be responsible for installing the MES noted as S-2 and S-8.

QUESTION #3

Are we to, Flush, Chlorinate and provide bacterial tests on the water line ?

ANSWER #3

Yes.

QUESTION #4

Are we to Clean and laser profile the Strom lines?

ANSWER #4

Contractor will be responsible for cleaning existing storm pipes and structures. No laser profile is required.

QUESTION #5

Any part of new septic system requires 75 feet set back of high water of surface water or wet retention ponds! I don't think the plans I reviewed will meet the above set backs! Please advise if there is a problem with the proposed septic location.?

ANSWER #5

The retention ponds that are within 75 feet from the septic system are dry ponds. We do not anticipate a problem with the location of the septic system as shown.

QUESTION #6

Will pre-bid sign in sheet become available?

ANSWER #6

Yes, upon request via email to Alisha.Morgan@MyFWC.com

QUESTION #7

Who was the building manufacturer of the Educational Center.

ANSWER #7

The Educational Center was built on site. It was not a pre-manufactured building.

Item 2: Update Contact for Confidentiality Exemption Form Submission

For an electronic copy of construction plans and all other associated documents please email a completed Confidentiality Exemption Form (Attachment A in the Solicitation Document) to **Alisha Morgan** (alisha.morgan@myfwc.com).

END ADDENDUM