



MEMORANDUM

ADDENDUM NO. 2

Date: February 24, 2020

To: Bidders

From: Amanda Cruz *AC*
Procurement Specialist
Florida's Turnpike Enterprise

Subject: DOT-ITB-20-8025-AC
GENERATOR, FUEL TANK AND AUTOMATIC TRANSFER SWITCH (ATS) REPLACEMENT
AT MID-BAY BRIDGE ADMINISTRATION BUILDING, SR 293, MILEPOST 5.0

Bidders and other interested parties are informed that the above referenced documents are hereby revised, changed and supplemented as set forth below:

1. Exhibit "A," Scope of Services, page A-3, Section 4.1 – B, Department Provided Generator, ATS and Fuel Tank, sub-section 1 has been amended to clarify the fencing requirements.

Please remove Exhibit "A," Scope of Services, page A-3 and replace it with the revised Exhibit "A," Scope of Services, page A-3, Dated February 24, 2020.

The Bidder shall acknowledge receipt of each addenda to this Invitation to Bid by completing Form No. 6, Addenda Acknowledgement Form and enclosing the same with your Bid Package. Please remember to replace the pages in your bid package with the attached revised pages.

Failure to file a protest within the time prescribed in Section 120.57(3), Florida Statutes, or failure to post the bond or other security required by law within time allowed for filing a bond shall constitute a waiver of proceedings under Chapter 120, Florida Statutes.

- A. Detailed scope of work is found in Attachment "A," Design Criteria.
- B. Department Provided Generator, ATS and Fuel Tank:
 - 1. The Vendor shall provide all labor, materials, equipment, transportation, and other related incidentals necessary for the installation of Department provided 80KW Cummins generator, automatic transfer switch (ATS) and 500-gal. ConVault fuel tank. ~~including aluminum fencing at Mid Bay Bridge Mainline Plaza, Niceville, Florida.~~ The Vendor shall furnish and install new aluminum fencing as specified in Attachment "A," Design Criteria.
 - 2. The Vendor shall completely de-energize and disconnect all fuel lines and electrical wiring of the existing generator system.
 - 3. If any scratches develop from the installation of the emergency generators, the generator shall be repainted or epoxy primed and coated before acceptance of the equipment.
 - 4. The Vendor shall furnish and install a battery charger and block heater specific to the unit and shall also be checked by the Vendor for proper operation.
- C. Portable Emergency Standby Generator:
 - 1. The Vendor shall supply a portable emergency standby generator at the location for use beginning when the existing generator system is disconnected until the installation of the Department provided generator is complete. A maximum of one (1) hour is allowed when making the final connections for the new generator and disconnecting the portable emergency standby generator. The Vendor shall make all efforts to minimize the time that the facility is without backup emergency power. Under no circumstances shall a site be without a working generator and ATS. Power outages shall be scheduled with the Department's Project/Contract Manager and the site Supervisor. Power outages shall not be performed during peak hours of traffic.
 - 2. The Vendor supplied portable standby emergency generator shall be connected, tested and fully operational. The Vendor shall ensure that portable emergency standby generators are properly maintained and fueled while in use and that the facility has continuous backup emergency power. It shall be the Vendor's responsibility to disconnect all portable emergency standby generators prior to making the final connection to the new generators.

4.2 General Notes and Other Requirements

- A. The Vendor shall examine the Contract documents and each site of the proposed work carefully before submitting a proposal for the work contemplated under this Contract. The Vendor shall investigate the conditions to be encountered, as to the character, quality, and quantities of work to be performed and materials to be furnished and as to the requirements of all Contract documents.
- B. Prior to beginning work under this Contract, the Vendor shall submit to the Department for approval, a copy of the Vendor's proposed plan and methods for performing the work, including a listing of equipment and personnel anticipated for use.
- C. The Vendor shall maintain adequate and competent personnel so as to enable the Vendor to complete the assigned work within the time period indicated in Section 7.0, Duration of Contract, of this Exhibit.
- D. The Vendor shall execute the work in an orderly and efficient manner. The Vendor shall proceed with the work with all due diligence and use all reasonable efforts to complete the same without delay; failure to do so may constitute unsatisfactory performance, and after written warning, the Vendor may be declared in default.
- E. The Vendor and sub-vendor shall ensure that all motor vehicles used on this project are registered and insured. All drivers shall be licensed in the State of Florida.