

Mission:
To protect, promote & improve the health
of all people in Florida through integrated
state, county & community efforts.



Ron DeSantis
Governor

Vision: To be the Healthiest State in the Nation

**Addendum #2
ITB DOH18-037
Automatic Transfer Switches**

DATE: May 21, 2019
TO: Prospective Vendors
FROM: Allegra Small, Procurement Officer
Florida Department of Health
Central Purchasing Office
SUBJECT: Addendum #2

The purpose of this addendum is to answer questions received in accordance with **section 2.8**, Questions, of the Invitation to Bid. This addendum serves as notice of the following change(s):

Deletions are indicated by “~~strike through~~” or reference. Additions, updates or replacements are indicated by **highlighting**.

A. Modifications: The following modifications are made to the ITB:

1. Page 5, section 2.3, Term:

It is anticipated that the Contract resulting from this ITB ~~will be for a one-year period from May 15, 2019~~ **will be for a three month term beginning June 1, 2019 through August 30, 2019**, ~~or the Contract execution date whichever is later, subject to renewal as identified in section 2.4.~~ The Contract resulting from this ITB is contingent upon availability of funds.

B. Responses to Questions received pursuant to section 2.8, Questions: Please see the Department’s response to questions received by the due date outlined in section 2.5. Timeline, of the ITB, below:

Addendum #2
 Questions and Answers
 ITB DOH18-037
 Automatic Transfer Switches

#	Question	Answer
1	Will back up power be needed during panel change outs?	Backup power will not be needed if the work causing the outage is completed after hours (after 6:00 PM Monday-Friday or Saturday and Sunday) and scheduled at least three business days in advance. If the outage will extend into the work day (Monday-Friday from 6:00 AM-6:00 PM) then backup power will need to be provided by the Vendor.
2	Work to be done after work hours M-F or weekends?	Any work that will cause a power outage to the existing service will need to be performed after hours (after 6:00 PM Monday-Friday or Saturday and Sunday) and will need to be scheduled at least three business days in advance.
3	On drawing E1.2 circuits GEN-1,3 and GEN-2 are these existing or new runs?	These circuits are existing and to remain.
4	On drawing E1.2 is the E-Stop #1 at the existing 600A ATS #2 existing or to be added?	This item is existing. Emergency Stop Buttons (E-stops) are to be added only at the three new ATS locations.
5	What is the length of contract after awarded; 6.1.1 show May 31, 2019?	All work will need to be completed by August 30, 2019.
6	Can a copy of the sign-in list of the mandatory site visit be provided?	The sign- in sheet from the mandatory site visit is attached.
7	Are ASCO or EATON acceptable ATS manufactures?	Yes, both are acceptable.

Addendum #2
 Questions and Answers
 ITB DOH18-037
 Automatic Transfer Switches

8	Will an engineering estimate be required?	No.
#	Question	Answer
9	What are the conduit sizes from generator to DP North?	The conduit size is shown on sheet E1.2 as AB700 in an oval symbol and correlates with the "ALUMINUM CONDUCTOR AND CONDUIT SCHEDULE" on the same sheet. It is the engineer's intention that the existing conduits are to be reused.
10	What are the conduit sizes from generator to DP South?	The conduit size is shown on sheet E1.2 as AB700 in an oval symbol and correlates with the "ALUMINUM CONDUCTOR AND CONDUIT SCHEDULE" on the same sheet. It is the engineer's intention that the existing conduits are to be reused.
11	Confirm cable requirements between copper & aluminum.	The conductor types are shown on sheet E1.2 in the "COPPER CONDUCTOR AND CONDUIT SCHEDULE" and "ALUMINUM CONDUCTOR AND CONDUIT SCHEDULE" as letters and numbers in an oval symbol. A&B are for copper conductors and AA&AB are for aluminum conductors.

Failure to file a protest within the time prescribed in section 120.57(3), Florida Statutes, or failure to post the bond or other security required by law within the time allowed for filing a bond shall constitute a waiver of proceedings under Chapter 120, Florida Statutes.

ATTENDANCE SHEET

Mandatory Site Visit
Invitation to Bid
DOH18-037
Automatic Transfer Switches
May 3, 2019 at 10:00 a.m., Eastern Time

PLEASE PRINT

ATTENDEE (Print Full Name)	BUSINESS NAME	FAX #/Phone	EMAIL
Bill Biscardi	Accurate power and Tech	352-257-3369	Bill@accuratepowerandtechnology.com
Mary Weber	Accurate Power and Tech		
Timothy Jarvis	Quest Design Group		tjarvis@questdg.com
Jon Shepard	Quest Design Group	941 351 9996	jstepard@questdg.com
David Shine	SHINE & COMPANY	386-454-2024	MATT@SHINECOMPANY.COM
Paul Brooks	INTERBAY ELECTRIC	813-625- 1111 876-0162	PAULB@INTERBAYELECTRIC.COM
Scott Searcy	Interbay Electric	727-288-4799	SCOTTS@interbayelectric.com
CHARLES ELLIOTT	THINK IT Ai	813-421-1606	CHARLES@THINKITAI.COM
HENRY CARPENTER	ZABATT	407-924-6378	HENRY.CARPENTER@ZABATT.COM
ALEX ACURRA	CPS GROUP	786-443-5955	SAURON@CPSGROUP.COM