



FLORIDA DEPARTMENT OF AGRICULTURE AND CONSUMER SERVICES
COMMISSIONER NICOLE "NIKKI" FRIED

June 11, 2019

ADDENDUM 1

TO: Vendors
FROM: Vianka Colin, Purchasing Director
**RE: INVITATION TO BID ITB/DM-18/19-75
REPAIRS AT IMMOKALEE STATE FARMERS MARKET**

This addendum is to provide all potential bidders with changes and answers to questions received in reference to Invitation to Bid ITB/DM-18/19-75. **Deletions are struck through, and additions are highlighted.**

Questions/Answers

1. Who determines which and how many fasteners are to be replaced?

The areas to be replaced will be determined by the architect, code official and general contractor. The unit price is for 100 replaced screws in the building. The total number replaced will have to be quantified after the job is complete.

2. Does this item 11 include fasteners to secure replacement panels as well as notes specific to the drawings that call for replacement fasteners?

No. This is just for removing damaged or missing fasteners and replacing them. Replacement panels should have their own cost.

3. Please provide a specification for bird screen replacement.

2 mesh intercrimp aluminum .063" or 1/2" galvanized mesh shall be used. Existing wire to be replaced at ridge cents as indicated on drawings.

To the extent this addendum gives rise to a protest, failure to file a protest within the time prescribed in Section 120.57(3), Florida Statutes, shall constitute a waiver of proceedings under Chapter 120, Florida Statutes. All other terms, conditions and specifications of this Invitation to Bid will remain the same. If you have any questions regarding this addendum, please feel free to contact this office at (850) 617-7181.