



**Florida Fish
and Wildlife
Conservation
Commission**

Commissioners
Robert A. Spottswood
Chairman
Key West

Michael W. Sole
Vice Chairman
Tequesta

Joshua Kellam
Palm Beach Gardens

Gary Lester
Oxford

Gary Nicklaus
Jupiter

Sonya Rood
St. Augustine

Office of the
Executive Director
Eric Sutton
Executive Director

Thomas H. Eason, Ph.D.
Assistant Executive Director

Jennifer Fitzwater
Chief of Staff

850-487-3796
850-921-5786 FAX

Finance and Budget Office
Kurt Fritsch
Finance & Budget

(850) 488-6551

*Managing fish and wildlife
resources for their long-term
well-being and the benefit
of people.*

620 South Meridian Street
Tallahassee, Florida
32399-1600
Voice: 850-488-4676

Hearing/speech-impaired:
800-955-8771 (T)
800 955-8770 (V)

MyFWC.com

DATE: APRIL 25, 2019

ADDENDUM NO.: 2

BID NO.: FWC 18/19-93C

BID TITLE: FUME HOOD, EXHAUST FAN AND AIR HANDLER UPGRADE
REBID

UPDATE: RESPONSES TO WRITTEN QUESTIONS

The enclosed addendum has been issued for consideration in the preparation of your response to the Florida Fish and Wildlife Conservation Commission's (FWC) Solicitation No. FWC 18/19-93C, "Fume Hood, Exhaust Fan and Air Handler Upgrade Rebid".

All responses to the subject solicitation must be received no later than 10:30 AM (EST) on Thursday, May 2, 2019.

A response received after the exact time specified will not be considered. Failure to file a protest within the time prescribed in Section 120.57(3), Florida Statutes (F.S.), or failure to post the bond or other security required by law within the time allowed for filing a bond shall constitute a waiver of proceedings under Chapter 120, Florida Statutes. Written notices, formal requests and proceedings must conform with the requirements set forth in Chapter 28-110, Florida Administrative Code (F.A.C.). Protests must be filed with the Purchasing Office, Fish and Wildlife Conservation Commission, 2590 Executive Center Circle, Tallahassee, Florida 32301 within the time prescribed in Section 120.57(3), F.S. and Chapter 28-110, F.A.C.

Sincerely,

Alisha Morgan

FWC Procurement Manager

BEGIN ADDENDUM

QUESTION #1

What types of acids (i.e., hydrofluoric, nitric, etc.) are used in the fume hoods?

ANSWER #1

Please see the 1st Floor Chemical List attachment on the Vendor Bid System (VBS).

QUESTION #2

Has an asbestos survey been done?

ANSWER #2

Yes, an asbestos survey has been done. Please see the Pre-Renovation Asbestos Survey Report attachment on VBS.

QUESTION #3

There are no electrical drawings although reference is made regarding electrical work.

ANSWER #3

Refer to Sheet M4.1, Lab Control General Notes, Note #2.

QUESTION #4

Is Viega Propress acceptable in lieu of soldered/brazed piping joints? This will eliminate open flame in the laboratories and the necessity for "burn permits".

ANSWER #4

Yes.

QUESTION #5

Exhaust fan remove & replace – Pg M1.1 Note 9 and Pg M2.1 Note 6. This fan was on previous plans on the 3rd floor. Do these notes apply?

ANSWER #5

Notes associated with Third Floor do not apply.

END ADDENDUM