

RFP-DOT-17-18-5010-PNT

Central Florida Rail Corridor (CFRC) Maitland Bridge Cleaning and Painting
Questions and Answers #3-Clarification

May 23, 2018

1. Will the contractor be allowed to fasten to the bottom of the rail road ties?

No attachment to the rail ties will be allowed