

**State of Florida  
Department of Transportation  
Florida's Turnpike Enterprise**

**INVITATION TO BID**

**DOT-ITB-19-8012-RM**

**RESPONSES TO QUESTIONS**

1. Generator enclosure is indicated as steel rather than aluminum, wind rating at 150 MPH. Prebid indicated aluminum. Please clarify.

*Response: We will create an addendum to correct this-enclosures are to be aluminum per current Turnpike standard.*

2. The duration of the contract is listed as 90 days which will commence within 60 days of contract award. Can the start of the 90 days be adjusted or the duration extended to accommodate the lead times of equipment? Current manufacturer lead times are 10-12 weeks and are often impacted by circumstances beyond the control of the contractor. Even if the contract commences at the same time the equipment is ordered the equipment lead time could use up most of the 90 day duration leaving only a few days to complete the installations.

*Response: We will create an addendum to add time to the duration before the notice to proceed which will account for the current lead times.*