



# Florida Department of Environmental Protection

Marjory Stoneman Douglas Building  
3900 Commonwealth Boulevard  
Tallahassee, Florida 32399-3000

Rick Scott  
Governor

Carlos Lopez-Cantera  
Lt. Governor

Noah Valenstein  
Secretary

May 11, 2018

## NOTICE TO APPLICANTS ADDENDUM NO. THREE (3)

### Cayo Costa State Park – Restroom Replacement Dep Bid NO. BDC27-17/18

TO BIDDERS AND PLAN HOLDERS ON THE ABOVE REFERENCED PROJECT: PLEASE NOTE CONTENTS HEREIN AND INCLUDE WITH YOUR BID SUBMISSION.

#### NOTICE

---

It will be required that this addendum be signed in acknowledgment of receipt and that it be included with your Bid when same is submitted to Adam Browne, Government Operations Consultant II, Bureau of Design and Construction, 3800 Commonwealth Blvd. MS520, Tallahassee, Florida 32399-3000. Failure to do so may be grounds for rejection of the Bid.

---

Signature of Contractor and Date

The Following statements supersede & supplement the corresponding items in the specifications & drawings:

- Question: The plans call for 16" piles for the structure foundation. The Geotech noted 12" piles. Would the department consider 12" piles or should the bid continue to include 16" piles?**  
**Response: Bid should include 16" piles per plans.**

In all other respects, the contract documents of which this is an Addendum, and attachments relative thereto, shall remain in full force and effect.