



FLORIDA DEPARTMENT *of* STATE

ADDENDUM NO. 1

October 13, 2017

Synthetic Thatch Roof Installation
Advertisement Number: DOS ITB 09/19-10

This Addendum now becomes a part of the original Request for Proposal.

Failure to file a protest within the time prescribed in Section 120.57(3), Florida Statutes, or failure to post the bond or other security required by law within the time allowed for filing a bond shall constitute a waiver of proceedings under Chapter 120, Florida Statutes (F.S.).

This Addendum includes the following:

1. Written Responses to Written Questions
2. Amended Attachment C – Price Bid Sheet

The remainder of this page is left intentionally blank

1. Written Responses to Written Questions

Vendor Question Number	ITB Page #, Section #, Subsection Reference	Vendor Question
1		<p>Who will be responsible for the removal and reinstallation of the lightning protection system?</p> <p>Answer: The successful vendor will be responsible for the proper removal and reinstallation of the lightning protection system. Vendor shall insure the system is reinstalled in accordance with the National Fire Protection Association (NFPA) 780: Standard for the Installation of Lightning Protection Systems.</p>
2		<p>Who will be responsible for the reinstallation of the bat exclusion system, if it is accidentally or intentionally dislodged?</p> <p>Answer: The bat exclusion system was installed in 2016 with the full knowledge that the church roof was leaking and would be rethatched soon. With that in mind, the exclusion system was designed so that the building could be reroofed without disturbing the bulk of this system. The successful vendor will do the re-roof <u>without removing</u> the bat exclusion system. In any minor portions where this is not possible or if any of the system is accidentally dislodged, then the exclusion devices/materials will be reattached or reinstalled by the roofing vendor. The successful vendor's roofing plan will be discussed with the bat exclusion company prior to work starting and any possible concerns will be addressed.</p>

Amended ATTACHMENT C - PRICE BID SHEET

Florida Department of State DOS ITB 09/17-10
Synthetic Thatch Roof Installation

Deliverables	Price
Endureed VIVA Series Synthetic Thatch and all materials and supplies	(a)
Phase 1 1 st half of current thatch removed and Endureed VIVA Series synthetic thatch installed	(b)
Phase 2 2 nd half of current thatch removed and Endureed VIVA Series synthetic thatch installed. This deliverable shall also include site clean up, removal of vendor's equipment, lightning protection reinstallation and reinstallation of bat exclusion netting and cracks/gaps sealed to prevent bat reentry as applicable.	(c)

(a) + (b) + (c) = Total for award \$ _____

Company Name: _____

Company Contact Name: _____ Contact Phone # _____

Address: _____

City: _____ State: _____ Zip: _____

Printed Name of Authorized Representative:

**This individual must have the authority to bind the Vendor.*

Signature of Authorized Representative:

Date: _____