



FLORIDA DEPARTMENT OF AGRICULTURE AND CONSUMER SERVICES
COMMISSIONER NICOLE "NIKKI" FRIED

February 18, 2019

ADDENDUM 2

TO: Vendors
FROM: Vianka Colin, Purchasing Director
**RE: INVITATION TO BID ITB/PI-18/19-53
QUARANTINE GREENHOUSE RENOVATION**

This addendum is to provide all potential bidders with answers to questions received in reference to Invitation to Bid ITB/PI-18/19-53. **Deletions are struck through, and additions are highlighted.**

Question / Answer

1. **On drawing sheet no. 06 is an Equipment Schedule for the Trane Package Units. The schedule is not filled out in reference to: (HP) (Volts), (PH), (AMP) or (RPM). In order to get a quote from Trane, the schedule needs to be completed.**

The required performance and specification guide are on the same sheet, sheet no. 06. The data for the exterior fan is 0.70 HP; Volts – TBD; PH – 1; AMP-depends on Voltage; 1,100 RPM. The voltage and amp draw will depend on the electric service available and corresponding Trane model TSC102 unit. Trane model TSC102F4RBA is listed on the Equipment Schedule.

To the extent this addendum gives rise to a protest, failure to file a protest within the time prescribed in Section 120.57(3), Florida Statutes, shall constitute a waiver of proceedings under Chapter 120, Florida Statutes. All other terms, conditions and specifications of this Invitation to Bid will remain the same. If you have any questions regarding this addendum, please feel free to contact this office at (850) 617-7181.