



## MEMORANDUM

### ADDENDUM NO. 3

Date: May 6, 2019

To: Bidders

From: Amanda Cruz *AC*  
Procurement Specialist  
Florida's Turnpike Enterprise

Subject: DOT-ITB-19-8010-AC  
Replacement of Emergency Standby Generator, Fuel Tank and Automatic Transfer Switch (ATS) at Various Locations Along the Florida's Turnpike System for the North Region

---

Bidders and other interested parties are informed that the above referenced documents are hereby revised, changed and supplemented as set forth below:

1. Attachment "C," Scope of Services and General Requirements Page 1, Section 1.01 has been revised to add an additional scope of work to Site No. 1 – Orlando South Maintenance Yard/FHP POST 7, Building 5260, SR 91 MP 254.0.
2. Attachment "C," Scope of Services and General Requirements Page 2, Section 1.01 has been revised to add an additional scope of work to Site No. 7 – SR 434 Southbound On Ramp, Building 5439, SR 417, MP 44.0 and to change the KW requirement from 50 to 30.

*Please remove Attachment "C," Scope of Services and General Requirements Pages 1 and 2 and replace with the revised Attachment "C," Scope of Services and General Requirements Pages 1 and 2, dated May 6, 2019.*

*The Bidder shall acknowledge receipt of each addenda to this Invitation to Bid by completing Form No. 6, Addenda Acknowledgement Form and enclosing the same with your Bid Package. Please remember to replace the pages in your bid package with the attached revised pages.*

Failure to file a protest within the time prescribed in Section 120.57(3), Florida Statutes, or failure to post the bond or other security required by law within the time allowed for filing a bond shall constitute a waiver of proceedings under Chapter 120, Florida Statutes.

## ATTACHMENT "C" SCOPE OF SERVICES AND GENERAL REQUIREMENTS

### Generator/Automatic Transfer Switch (ATS) Replacement at Seven (7) Sites - North Region

#### PART 1.00 - GENERAL

##### 1.01 WORK INCLUDED

###### Site; General Scope of work

- 1) Orlando South Maintenance Yard/FHP POST 7, Building 5260, SR 91 MP 254.0
  - The Vendor shall remove and dispose of the existing standby generator, ATS and 500 gal. Liquid Propane (LP) tank.
  - The Vendor shall furnish and install new indoor LP, 35 KW 120/208 volts three phase, three wire standby generator.
  - The Vendor shall furnish and install new 150 AMP three phase ATS unit.
  - The Vendor shall furnish and install new 1,000-gallon LP tank as specified in this Contract. See Attachment "D," Typical Fuel Tank Mounting Details.
  - The Vendor shall install new propane regulators in accordance with the generator's factory specifications.
  - The Vendor shall fill the new 1,000-gallon LP tank with fuel to 95% full.
- 2) U.S. 27 Southbound Ramp Off Toll Plaza, Building 5456, SR 91 MP 289.0
  - The Vendor shall remove and dispose of the existing standby generator and ATS.
  - The Vendor shall furnish and install new outdoor Liquid Propane LP, 60 KW 120/240 volts single phase standby generator.
  - The Vendor shall furnish and install new 400 AMP single phase ATS unit.
  - The Vendor shall install new propane regulators in accordance with the generator's factory specifications.
  - Use existing LP tank for fuel.
- 3) U.S. 27 Northbound On Ramp Toll Plaza, Building 5454, SR 91 MP 289.0
  - The Vendor shall remove and dispose of the existing standby generator and ATS.
  - The Vendor shall furnish and install new outdoor LP, 60 KW 120/240 volts single phase standby generator.
  - The Vendor shall furnish and install new 400 AMP single phase ATS unit.
  - The Vendor shall install new propane regulators in accordance with the generator's factory specifications.
  - Use existing LP tank for fuel.

## ATTACHMENT "C" SCOPE OF SERVICES AND GENERAL REQUIREMENTS

- 4) **Celebration/SR 192 Southbound Off Ramp, Building 5467, SR 417 MP 2.0**
  - The Vendor shall remove and dispose of the existing standby generator and ATS.
  - The Vendor shall furnish and install new outdoor LP, 60 KW 120/240 volts single phase standby generator.
  - The Vendor shall furnish and install new 400 AMP single phase ATS unit.
  - The Vendor shall install new propane regulators in accordance with the generator's factory specifications.
  - Use existing LP tank for fuel.
  
- 5) **Celebration/SR 192 Northbound On Ramp, Building 5466, SR 417, MP 2.0**
  - The Vendor shall remove and dispose of the existing standby generator and ATS.
  - The Vendor shall furnish and install new outdoor LP, 60 KW 120/240 volts single phase standby generator.
  - The Vendor shall furnish and install new 400 AMP single phase ATS unit.
  - The Vendor shall install new propane regulators in accordance with the generator's factory specifications.
  - Use existing LP tank for fuel.
  
- 6) **Osceola Southbound Off Ramp, Building 5471, SR 417, MP 3.0**
  - The Vendor shall remove and dispose of the existing standby generator and ATS.
  - The Vendor shall furnish and install new outdoor LP, 50 KW 120/240 volts single phase standby generator.
  - The Vendor shall furnish and install new 400 AMP single phase ATS unit.
  - The Vendor shall install new propane regulators in accordance with the generator's factory specifications.
  - Use existing LP tank for fuel.
  
- 7) **SR 434 Southbound On Ramp, Building 5439, SR 417, MP 44.0**
  - The Vendor shall remove and dispose of the existing standby generator including the belly fuel tank and ATS.
  - The Vendor shall furnish and install new outdoor diesel, 30 KW 120/208 volts three phase standby generator with 250-gallon belly type diesel fuel tank.
  - The Vendor shall furnish and install new 150 AMP single phase ATS unit.
  - The Vendor shall fill the new 250-gallon belly type diesel tank with fuel to 95% full.