

FLORIDA DEPARTMENT OF TRANSPORTATION

**Procurement Office
605 Suwannee Street, MS 20
Tallahassee, Florida 32399-0450**

ADDENDUM NO. 1

DATE: May 29, 2019

**RE: Technical Questions and Answers
DOT-ITB-19-9091-GH
Tea Tables**

Q: What size LP Tank is Amerigas to supply and install?

A: The LP Tank shall be 1,000 gallons to meet the dimension requirements of the Contract Plans, Sheet TT-7 of 17.

Also, per the Section 3.4, paragraph 3, NOTE: The LPG tank shall be installed by the local propane retailer as delineated in the Contract Plans. The Vendor shall be responsible for procuring and coordinating this effort.

Proposers should acknowledge receipt of this Addendum by completing and submitting with their proposal (or Addendum may be sent via email to greg.hill@dot.state.fl.us) no later than the time and date of the proposal opening.

Bidder/Proposer

Submitted by (Signature)

Failure to file a protest within the time prescribed in Section 120.57(3), Florida Statutes, or failure to post the bond or other security required by law within the time allowed for filing a bond shall constitute a waiver of proceedings under Chapter 120, Florida Statutes.