

Jeff Atwater
CHIEF FINANCIAL OFFICER

Julius Halas
DIVISION DIRECTOR



Casia Sinco
BUREAU CHIEF

FLORIDA DEPARTMENT OF FINANCIAL SERVICES
DIVISION OF STATE FIRE MARSHAL
200 East Gaines Street - Tallahassee, Florida 32399-0342
Tel. 850-413-3644 Fax. 850-410-2467

December 13, 2016

CHRISTY DALY, SECRETARY
DEPARTMENT OF JUVENILE JUSTICE
KNIGHT BUILDING 2737 CENTERVIEW DRIVE
TALLAHASSEE, FL 32399-3100

FIRE INSPECTION

Parcel #: S-34-0021
Site Name: SPRING LAKE YOUTH
ACADEMY
Inspection Date: 12/12/2016
County:
Permit #:

Attention: SECRETARY

Dear Sir/Madam:

In the interest of life safety for the above named facility a Life Safety Inspection was conducted on 12/12/2016. The violations listed on the attached report are required to be corrected. Please provide this office with documentation concerning the status of these violations in accordance with the deadlines given for each violation listed on the report.

If a "Plan of Corrective Action" form is attached, it must be completed and returned to this office by the date specified in the deadline on the report. The required information includes the corrective action you plan, and an estimated date by which the correction will be completed.

Thank you for sharing our fire safety concerns. If you should have any further questions concerning this matter, please contact me.

Sincerely,

Richard Witmer, Fire Protection Specialist
4700 Terminal Drive, Unit #4
Ft. Myers FL33907
Phone: 239-278-7549 Fax: 850-414-6119
Email: richard.witmer@myfloridacfo.com

RECEIVED

DEC 14 2016

FACILITY SERVICES

cc: File



DEPARTMENT OF FINANCIAL SERVICES

Division of State Fire Marshal - Bureau of Fire Prevention

Fire Safety Inspection Report

Site Address:

Parcel #: S-34-0021
 SPRING LAKE YOUTH ACADEMY
 8806 SW START CENTER STREET HIGHWAY
 769
 ARCADIA, FL 34269

Agency Address:

DEPARTMENT OF JUVENILE JUSTICE
 KNIGHT BUILDING
 2737 CENTERVIEW DRIVE
 TALLAHASSEE, FL 32399-3100
 Phone: 850-413-7313
 Fax:

Safety Coordinator Address:

WILLIAM GRAVELY
 DEPARTMENT OF JUVENILE JUSTICE
 2737 CENTERVIEW DRIVE
 TALLAHASSEE, FL 32399-3100
 Phone: 850-717-2751
 Fax:

Inspection Date: 12/12/2016

Inspector: Richard Witmer

Inspections Performed

File #: S-34-0021-0001 **Building Name:** ADMINI/DORMITORY CAMBIO 2

Inspection Type: Fire Alarm Inspection **Building #:** 4937

Inspection Status: Pass

Inspection Notes: Tested new fire alarm panel.

No Violations Found

File #: S-34-0021-0001 **Building Name:** ADMINI/DORMITORY CAMBIO 2

Inspection Type: High Hazard Inspection **Building #:** 4937

No Violations Found

File #: S-34-0021-0001 **Building Name:** ADMINI/DORMITORY CAMBIO 2

Inspection Type: Other Inspection **Building #:** 4937

Inspection Status: Pass

Inspection Notes: Tested sprinkler systems communication with new fire alarm panel.

No Violations Found

File #: S-34-0021-0002 **Building Name:** VOCATIONAL BUILDING CAMBIO 1

Inspection Type: High Hazard Inspection **Building #:** 4938

No Violations Found

File #: S-34-0021-0005 **Building Name:** KITCHEN

Inspection Type: High Hazard Inspection **Building #:** 4912

Violations Found

1. FACP CIRCUIT BREAKER NOT MARKED/SECURED
 Need to lock circuit breaker to fire alarm
 Required compliance date: 01/11/2017
2. OPEN ELECTRICAL JUNCTION BOX /PANEL
 Need to put cover on electric box in dinning room.

Required compliance date: 01/11/2017

3. GENERAL REQUIREMENTS

Need to secure toaster oven from being push back into electric wirers behind oven.

Required compliance date: 01/11/2017

4. GENERAL REQUIREMENTS

3 GFI's in kitchen need to be replaced they are worn and not working correctly.

Required compliance date: 01/11/2017

5. GENERAL REQUIREMENTS

Ceiling light in storage room needs to have bulbs in all sockets.

Required compliance date: 01/11/2017

File #: S-34-0021-0008 **Building Name:** MAINTENANCE BUILDING
Inspection Type: Recurring Inspection **Building #:** 4945

No Violations Found

File #: S-34-0021-0009 **Building Name:** STORAGE CANOE EQUIPMENT
Inspection Type: Recurring Inspection **Building #:** 4940

No Violations Found

File #: S-34-0021-0019 **Building Name:** HAZMAT STORAGE LOCKERS
Inspection Type: Recurring Inspection **Building #:** NL 10

No Violations Found

File #: S-34-0021-0020 **Building Name:** SHED RAPELLING
Inspection Type: Recurring Inspection **Building #:** NL-1

No Violations Found

File #: S-34-0021-0021 **Building Name:** ADMINISTRATIVE BUILDING
Inspection Type: Recurring Inspection **Building #:**

No Violations Found