



FLORIDA DEPARTMENT OF Environmental Protection

Marjory Stoneman Douglas Building
3900 Commonwealth Boulevard
Tallahassee, Florida 32399-3000

Rick Scott
Governor

Carlos Lopez-Cantera
Lt. Governor

Noah Valenstein
Secretary

February 11, 2019

NOTICE TO APPLICANTS ADDENDUM NO. FIVE (5)

Rookery Bay National Estuarine Research Reserve – Goodland Field Station Replacement DEP BID NO. BDC19-18/19

TO BIDDERS AND PLAN HOLDERS ON THE ABOVE REFERENCED PROJECT: PLEASE NOTE CONTENTS HEREIN AND INCLUDE WITH YOUR BID SUBMISSION.

NOTICE

It will be required that this addendum be signed in acknowledgment of receipt and that it be included with your Bid when same is submitted to Alyssa Skehan, Government Operations Consultant II, Bureau of Design and Construction, 3800 Commonwealth Blvd. MS520, Tallahassee, Florida 32399-3000. Failure to do so may be grounds for rejection of the Bid.

Signature of Contractor and Date

- **The following are revised answers to the questions provided in Addendum #4**

The Following statements supersede & supplement the corresponding items in the specifications & drawings:

1. **Question:** Who is responsible for kitchen and laundry appliances?
Answer: Appliances are specified in the Equipment Schedule / sht. A604. The Contractor must include in their bid an estimate for the appliances being purchased.
2. **Question:** Drawing P101 shows a 1 & ½ inch domestic water line. The Civil Drawings do not show an existing domestic water line. Is the domestic water line new and to be tapped into the 8” collier county water main at the same location as the fire line?

Answer: The answer is regarding the connection to the domestic water line. The contractor will disconnect the existing domestic water and reconnect it to the new building. There is a fire hydrant located on the property as shown on the survey.

In all other respects, the contract documents of which this is an Addendum, and attachments relative thereto, shall remain in full force and effect.