



FLORIDA DEPARTMENT OF Environmental Protection

Marjory Stoneman Douglas Building
3900 Commonwealth Boulevard
Tallahassee, FL 32399

Ron DeSantis
Governor

Jeanette Nuñez
Lt. Governor

Noah Valenstein
Secretary

February 14, 2020

NOTICE TO APPLICANTS ADDENDUM NO. ONE (1)

Oleta River State Park – Sewer Connections DEP Bid NO. BDC29-19/20

TO BIDDERS AND PLAN HOLDERS ON THE ABOVE REFERENCED PROJECT: PLEASE NOTE CONTENTS HEREIN AND INCLUDE WITH YOUR BID SUBMISSION.

NOTICE

It will be required that this addendum be signed in acknowledgment of receipt and that it be included with your Bid when same is submitted to Alyssa Skehan, Government Operations Consultant II, Bureau of Design and Construction, 3900 Commonwealth Blvd. MS520, Tallahassee, Florida 32399-3000. Failure to do so may be grounds for rejection of the Bid.

Signature of Contractor and Date

The Following statements supersede & supplement the corresponding items in the specifications & drawings:

- 1. Question:** Can the State list an allowance for permit fees? Cost assessment from building departments are rather dubious and may fluctuate based on agency perception.
Answer: No.
- 2. Question:** Will a staging area be provided?
Answer: Yes, an area for staging will be provided
- 3. Question:** Is directional bore an option?
Answer: No, the directional bore construction method is not an option.

4. **Question:** Is excavated material the responsibility of the contractor or the owner?
Answer: Excavated material must be removed from the park, unless specified on the plans.
5. **Question:** Is there any connection fee to FPL? If so, will the owner reimburse the contractor?
Answer: No, the owner will pay the connection fee to FPL.
6. **Question:** Will the City grant an extension on RFI? To 7 days before the bid date?
Answer: Questions about “the City” are not applicable to this advertisement. However, the State will postpone the bid opening until 2/26/2020. See below.

The bid submittal due date and bid posting date for this bid has been postponed per the below:

BID SUBMITTAL DUE DATE: No later than **3:30 PM (ET), Wednesday, February 26, 2020** to the below address: Florida Department of Environmental Protection, Bureau of Design and Construction, 3800 Commonwealth Blvd. MS520, Tallahassee, Florida 32399-3000, Attention Alyssa Skehan, Government Operations Consultant II, Bureau of Design and Construction, (850) 245-278. (For hand delivery: Carr Building, Welcome Desk.) The Department reserves the right to reject any or all bids.

BID POSTING DATE: No later than **3:30 PM (ET), Wednesday, March 4, 2020**, unless extended by the Department for good cause.

In all other respects, the contract documents of which this is an Addendum, and attachments relative thereto, shall remain in full force and effect.