

Invitation to Bid 19-ITB-007-SS
Roof Replacement and Designated Repairs of Fuller Warren Building
Technical Questions and Answers

Please note that the Department's responses are not **final, official or binding**. Violation of section 287.057(23) of the Florida Statutes, by a respondent to a solicitation, or persons acting on their behalf, may be grounds for rejecting a response. The Department's responses to timely submitted questions are provided below:

| Question Number | Page Number, Section | Question | Answers |
|-----------------|----------------------|---|--|
| 1 | | Section 2.2 and 2.3 on 07 54 16 – 9 addresses the application of a base sheet, but there is no reference to a base sheet on any of the details or in the description of work. Please clarify where the base sheet will be required (if at all). | Reference to base sheet to be dis-regarded Troy Giebert A/R/C Associates - 10/21/2019 |