



Florida Fish and Wildlife Conservation Commission

Commissioners
Bo Rivard
Chairman
Panama City

Robert A. Spottswood
Vice Chairman
Key West

Richard Hanas
Oviedo

Gary Nicklaus
Jupiter

Sonya Rood
St. Augustine

Michael W. Sole
Tequesta

Executive Staff
Eric Sutton
Executive Director

Thomas H. Eason, Ph.D.
Assistant Executive Director

Jennifer Fitzwater
Chief of Staff

Finance and Budget Office
Jodi Bailey
Chief Operating Officer

(850) 488-6551
(850) 922-8060 FAX

Managing fish and wildlife resources for their long-term well-being and the benefit of people.

620 South Meridian Street
Tallahassee, Florida
32399-1600
Voice: (850) 488-4676

Hearing/speech-impaired:
(800) 955-8771 (T)
(800) 955-8770 (V)

MyFWC.com

DATE SEPTEMBER 18, 2019

ADDENDUM NO. 2

BID NO. FWC 19/20-10C

BID TITLE LWR (CARTER'S CREEK IMPROVEMENTS)

UPDATE QUESTIONS AND ANSWERS

The enclosed addendum has been issued for consideration in the preparation of your response to the Florida Fish and Wildlife Conservation Commission's (FWC) Solicitation No. FWC 19/20-10C, "LWR (CARTER'S CREEK IMPROVEMENTS)".

All responses to the subject solicitation must be received no later than 3:30 PM (EST) on Friday, September 27, 2019.

A response received after the exact time specified will not be considered. Failure to file a protest within the time prescribed in Section 120.57(3), Florida Statutes, or failure to post the bond or other security required by law within the time allowed for filing a bond shall constitute a waiver of proceedings under Chapter 120, Florida Statutes (F.S.). Written notices, formal requests and proceedings must conform with the requirements set forth in Chapter 28-110, Florida Administrative Code (F.A.C.). Protests must be filed with the Purchasing Office, Fish and Wildlife Conservation Commission, Suite 100, 2590 Executive Center Circle, Tallahassee, Florida 32301 within the time prescribed in Section 120.57(3), Florida Statutes and Chapter 28-110, Florida Administrative Code.

Sincerely,

Cody Massa
FWC Procurement Manager

Question: Can any scrapings, soils, trees be spread out on site or does all have to be removed?

Answer: All must be removed from site and disposed of in a legal manner.

Question: Can you provide a detail pointing out which trees that you want protected?

Answer: There are no specific trees that need to be protected, however, care should be taken to reduce the damage to any trees that are not located directly in the area for the proposed road and swale construction.

Question: Drawings say to reuse the WBeams on the guardrails. One is bent do you want it straightened and reused or replace that section?

Answer: WBeam can be straightend and reused.

Question: Will FWC provide us a staging area for materials?

Answer: Yes, we will designate an area at the South entrance.

Question: Plans call out 2' of sod, what type of sod?

Answer: Omit sod and replace with plugs of Wiregrass (*Aristida stricta*) planted at an appropriate density and 6" spacing.

Question: Do we seed/mulch all disturbed areas? If so, what type seed?

Answer: Yes, seed with Wiregrass (*Aristida stricta*) and mulch with a certified weed free, nontoxic, biodegradable material.

Question: Do Contractors need to prequalify with FWC prior to bidding?

Answer: Contractor must pre-quality with the Florida Fish & Wildlife Conservation Commission, per section B-1, Prequalification to Submit a Bid, of the General Terms and Conditions.

