



**Florida Fish
and Wildlife
Conservation
Commission**

Commissioners

Bo Rivard
Chairman
Panama City

Robert A. Spottswood
Vice Chairman
Key West

Joshua Kellam
Palm Beach Gardens

Gary Lester
Oxford

Gary Nicklaus
Jupiter

Sonya Rood
St. Augustine

Michael W. Sole
Tequesta

Executive Staff

Eric Sutton
Executive Director

Thomas H. Eason, Ph.D.
Assistant Executive Director

Jennifer Fitzwater
Chief of Staff
Finance and Budget Office

Jodi Bailey
Chief Operating Officer

(850) 488-6551
(850) 922-8060 FAX

*Managing fish and wildlife
resources for their long-term
well-being and the benefit
of people.*

620 South Meridian Street
Tallahassee, Florida
32399-1600
Voice: (850) 488-4676

Hearing/speech-impaired:
(800) 955-8771 (T)
(800) 955-8770 (V)

MyFWC.com

DATE: SEPTEMBER 26, 2018

ADDENDUM NO.: 3

BID NO.: FWC 18/19-13C

BID TITLE: FEC (RETAINING WALL)

UPDATE: QUESTION AND ANSWER (ITEM #1).

The enclosed addendum has been issued for consideration in the preparation of your response to the Florida Fish and Wildlife Conservation Commission's (FWC) Solicitation No. FWC 18/19-13C, "FEC (Retaining Wall)".

All responses to the subject solicitation must be received no later than 3:00 PM (EST) on Friday, October 05, 2018.

A response received after the exact time specified will not be considered. Failure to file a protest within the time prescribed in Section 120.57(3), Florida Statutes, or failure to post the bond or other security required by law within the time allowed for filing a bond shall constitute a waiver of proceedings under Chapter 120, Florida Statutes (F.S.). Written notices, formal requests and proceedings must conform with the requirements set forth in Chapter 28-110, Florida Administrative Code (F.A.C.). Protests must be filed with the Purchasing Office, Fish and Wildlife Conservation Commission, Suite 100, 2590 Executive Center Circle, Tallahassee, Florida 32301 within the time prescribed in Section 120.57(3), Florida Statutes and Chapter 28-110, Florida Administrative Code.

Sincerely,

Bryan Tucker

Bryan Tucker
FWC Procurement Manager

ITEM 1 –QUESTION AND ANSWER:

QUESTION #1: Is there an engineer's estimate or budget value or this project?

ANSWER #1: No engineer's estimate. PASO estimated \$40k for the construction.

QUESTION #2: There is no direct transition piece for the change from the SG225 Sheets to the SG750 sheets (I've attached and highlighted the are in question). CMI recommends a Shoreguard 550 corner as the best option for transition between the two different profiles. The SG225 sheet will be slightly loose in the connector while the SG750 sheet will need to have its connection trimmed down to fit. The caps will not line up either as they are also a different profile. Please see the following from the CMI Rep Jim Kanuch:

"It seems the best solution we can come up with would be to use our SG550 corner for this situation. The SG225 & SG750 are on completely different spectrums of our vinyl sheet pile portfolio. You will more than likely need to use a sealant of some kind to fill the gap in attaching the SG550 corner to the SG225 sheet pile. You will also likely need to trim the SG750 sheet pile male lock to insert into this corner piece."

Please advise if their proposed solution is acceptable or provide an alternative. Should you have any questions feel free to contact him direct at 814.243.2516 or via email at jkanuch@cmilc.com.

ANSWER #2: See sheet label - 17-17-110-40 TA#11 FEC (retaining wall) _Structural SK-01, attached to the Vendor Bid System advertisement for the engineer's solution to question #2.

END OF ADDENDUM