



Florida Department of Environmental Protection

Marjory Stoneman Douglas Building
3900 Commonwealth Boulevard
Tallahassee, Florida 32399-3000

Rick Scott
Governor

Carlos Lopez-Cantera
Lt. Governor

Noah Valenstein
Secretary

September 6, 2018

NOTICE TO APPLICANTS ADDENDUM NO. TWO (2)

Caladesi Island State Park – Bulkhead Replacement Phase III Dep Bid NO. BDC10-18/19

TO BIDDERS AND PLAN HOLDERS ON THE ABOVE REFERENCED PROJECT: PLEASE NOTE CONTENTS HEREIN AND INCLUDE WITH YOUR BID SUBMISSION.

NOTICE

It will be required that this addendum be signed in acknowledgment of receipt and that it be included with your Bid when same is submitted to Adam Browne, Government Operations Consultant II, Bureau of Design and Construction, 3800 Commonwealth Blvd. MS520, Tallahassee, Florida 32399-3000. Failure to do so may be grounds for rejection of the Bid.

Signature of Contractor and Date

The Following statements supersede & supplement the corresponding items in the specifications & drawings:

Question: The existing conditions are such that the tie back rods are galvanized and not aluminum. Is it fair to assume that Phase 3 will be constructed in the same manner as previous phases?

Response: Match previous phase construction, or approved equal. Product must be submitted to the Project Manager for approval prior to installation.

In all other respects, the contract documents of which this is an Addendum, and attachments relative thereto, shall remain in full force and effect.