

ADDENDUM No. 1

**FLORIDA DEPARTMENT OF ENVIRONMENTAL PROTECTION
DEP Procurement Section
3800 Commonwealth Boulevard, MS#93
Tallahassee, Florida 32399-3000**

July 29, 2019

**Addendum To: DEP Solicitation No. 2019023 REBID, entitled
Plumbing Connection Services in Citrus County**

The Department hereby answers questions posed by prospective Vendors. Unless expressly indicated, these answers do not amend the terms of the solicitation. This addendum does not need to be returned with the bid. The Department hereby answers the following questions:

Question #	Solicitation Section	Solicitation Page #	Question / Answer
1.	-	-	Are we supplying all the PRV's and back flow preventers I have done one in the past the County supplied the Back flow and we supplied the PRV. <i>Answer #1: All contractors are required to supply their own PRV and Backflow devices. Citrus County utility can provide guidance for appropriate use of devices.</i>
2.	-	-	We would like to know if a General Contractor and or utility Underground Contractor with experience with in the type of services requested could participate? <i>Answer #2: Yes, as long as the contractor meets all requirements identified within the ITB.</i>
3.	Section 5 Price Sheet Form	23	Line item #14 doesn't provide any sizes. That number can vary similar to the RPZ valves based on size. Do you have specific sizes available for a better breakdown on our prices? <i>Answer #3: ½"-2".</i>
4.	Section 3 Scope of Services	13	Do you require interested vendors to include a meter box to cover the in ground shutoff valve after the city meter? <i>Answer #4: Not required by the state for this specific solicitation; however, may be required by Citrus County, please check with Citrus County Utilities for more info.</i>
5.	Section 1 Introduction	4	Is there any expected completion date for the entire project?

Question #	Solicitation Section	Solicitation Page #	Question / Answer
			<i>Answer #5: Completion dates and deadlines will be discussed when contract is awarded to the selected vendor.</i>
6.	Section 3 Scope of Services	13	<p>We would like to use pex in place of pvc to avoid any fittings from meter to residence or commercial spaces. Is that possible?</p> <p><i>Answer #6: Yes, you may quote either PEX or PVC. Any material that is equivalent or superior to PVC may be used for the work on the contract.</i></p>

– Remainder of Page Intentionally Left Blank –