



Florida Army National Guard
Construction & Facility Management Office



ISSUED ADDENDUM

Date	October 14, 2021
ADDENDUM Number	1
Project Number and Name	219050 CBJTC Building 1000 Grey House Roof
Invitation to Bid Date	September 15, 2021
Number of Attachments	4
Bid Opening Date and Time	October 21, 2021 2:00PM

From: Department of Military Affairs, CFMO Contracting Office

This addendum and the listed attachments forms a part of the contract documents and modifies the original bidding documents. Acknowledgement of this addendum in Exhibit 4 - Bid Proposal form is required.

Concerns with this addendum should be addressed to:
ng.fl.flarng.list.cfmo-contracting@mail.mil

Answers to Questions (Q) / Clarifications (C) / Modifications (M)

- C1. Qualified bidders will be Building or General Contractors.
- C2. Unforeseen damage to roof – There is already an allowance in the plans / specs for unforeseen damage to the roof. Base bid to include replacing 160 SF of deteriorated wood roof decking.
- C3. Unforeseen damage to fascia – There is already an allowance in the plans / specs for unforeseen damage to the fascia.
- C4. There are no “quiet work hours” on this job, i.e. no restrictions on start time.
- C5. Contractors can work Monday - Friday, including AWS Mondays.
- C6. Background checks will be performed on all workers entering Camp Blanding. These checks are done at the welcome center (Provost Marshalls Office).

Attachment List

- 1. Pre-Bid Meeting Agenda

2. Pre-Bid Meeting Sign-In Sheet
3. Pre-Bid Meeting Minutes
4. REVISED Invitation to Bid

END OF ADDENDUM #1