



FLORIDA DEPARTMENT OF Environmental Protection

Marjory Stoneman Douglas Building
3900 Commonwealth Boulevard
Tallahassee, FL 32399

Ron DeSantis
Governor

Jeanette Nuñez
Lt. Governor

Shawn Hamilton
Secretary

January 4, 2022

NOTICE TO APPLICANTS ADDENDUM NO. THREE (3)

Highlands Hammock State Park – Residence Electrical & Plumbing Upgrades DEP Bid NO. BDC19-21/22

TO BIDDERS AND PLAN HOLDERS ON THE ABOVE REFERENCED PROJECT: PLEASE NOTE CONTENTS HEREIN AND INCLUDE WITH YOUR BID SUBMISSION.

NOTICE

It will be required that this addendum be signed in acknowledgment of receipt and that it be included with your Bid when same is submitted to Debbie Boyette, Government Operations Consultant II, Bureau of Design and Construction, 3900 Commonwealth Blvd. MS520, Tallahassee, Florida 32399-3000. Failure to do so may be grounds for rejection of the Bid.

Signature of Contractor and Date

The Following statements supersede & supplement the corresponding items in the specifications & drawings:

The New VTRs and SK Routing are hereby incorporated into the bid package and supersede those originally posted with the bid documents. Due to size restrictions on the Vendor Bid System, these documents can be found on the plans website. Please contact the Bureau of Design and Construction's Contracts Section at Deborah.Boyette@FloridaDEP.gov with any questions.

The following changes have been made to the contract documents:

- **The days to substantial completion are 120 days.**
- **Contractor to abate/remove asbestos containing floor material in kitchen and dining area of BL036001 and replace with new flooring.**
- **Roof and asbestos report**
- **New VTRs and SK Routing**

In all other respects, the contract documents of which this is an Addendum, and attachments relative thereto, shall remain in full force and effect.



REPORT OF BULK SAMPLE ANALYSIS FOR ASBESTOS

TESTED FOR: **PSI, Inc**
5801 Benjamin Center Drive Suite 112
Tampa, FL 33634
Attn: Robert Mundy

Project ID: **05523339-1**
Michael Baker International
Highlands Hammock State Pa
8 Structures, Sebring, FL

Date Received: **12/20/2021**

Date Completed: **12/20/2021**

Date Reported: **12/20/2021**

Analyst: **Dan Anderson** Work Order: **2112443** Page: **1 of 1**

Client ID	Lab ID (Layer)	Sample Description (Color, Texture, Etc.) <i>Analyst's Comment</i>	Asbestos Content (Percent and Type)	Non-asbestos Fibers (Percent and Type)
01	001A	(1) Black, Shingle, Homogeneous (2) Black, Felt, Homogeneous	NO ASBESTOS DETECTED NO ASBESTOS DETECTED	10% Fibrous Glass 45% Cellulose Fiber
02	002A	(1) Black, Shingle, Homogeneous (2) Black, Felt, Homogeneous	NO ASBESTOS DETECTED NO ASBESTOS DETECTED	10% Fibrous Glass 45% Cellulose Fiber
03	003A	(1) Black, Shingle, Homogeneous (2) Black, Tar, Homogeneous	NO ASBESTOS DETECTED NO ASBESTOS DETECTED	10% Fibrous Glass None Reported
04	004A	(1) Black, Shingle, Homogeneous (2) Black, Tar, Homogeneous	NO ASBESTOS DETECTED NO ASBESTOS DETECTED	10% Fibrous Glass None Reported
05	005A	(1) Black, Shingle, Homogeneous (2) Black, Tar, Homogeneous (3) Black, Felt, Homogeneous	NO ASBESTOS DETECTED NO ASBESTOS DETECTED NO ASBESTOS DETECTED	10% Fibrous Glass None Reported 45% Cellulose Fiber
06	006A	(1) Black, Shingle, Homogeneous (2) Black, Tar, Homogeneous (3) Black, Felt, Homogeneous	NO ASBESTOS DETECTED NO ASBESTOS DETECTED NO ASBESTOS DETECTED	10% Fibrous Glass None Reported 45% Cellulose Fiber
07	007A	(1) Black, Shingle, Homogeneous (2) Black, Felt, Homogeneous	NO ASBESTOS DETECTED NO ASBESTOS DETECTED	10% Fibrous Glass 75% Cellulose Fiber
08	008A	(1) Black, Shingle, Homogeneous (2) Black, Felt, Homogeneous	NO ASBESTOS DETECTED NO ASBESTOS DETECTED	10% Fibrous Glass 75% Cellulose Fiber

Report Notes: **(PT) Point Count Results**

Quantitation is based on a visual estimation of the relative area of bulk sample components, unless otherwise noted in the "Comments" section of this report. The results are valid only for the item tested as received. This report may not be used to claim product endorsement by NVLAP or any agency of the U.S. Government. Method used: E.P.A. Interim Method for the Determination of Asbestos in Bulk Insulation Samples (EPA 600/M4-82-020). Polarized Light Microscopy is not consistently reliable in detecting asbestos in floor coverings and similar non-friable organically bound materials. Quantitative Transmission Electron Microscopy is currently the only method that can be used to determine if the material can be considered or treated as non-asbestos containing. Samples will be disposed of within 30 days unless notified in writing by the client. No part of this report may be reproduced, except in full, without written permission of the laboratory. The reporting limit is 1% by weight. NVLAP Lab Code 101350-0.

Respectfully submitted,
PSI, Inc.

Approved Signatory
Cathy McNamee