

**State of Florida
Department of Transportation
Florida's Turnpike Enterprise**

INVITATION TO BID

DOT-ITB-21-8022-RM

RESPONSES TO QUESTIONS

GROUP 2

1. Yeehaw Junction & Kenansville sites are the two generators open skid and liquid cool or are the enclosures left on and they are air cooled/The 20 kw comes in an enclosure and is air cooled, but Kohler does have a 24kw that is liquid cooled.

***Response:** The generators at Yeehaw and Kenansville are open and skid mounted installed inside of a block building. The Vendor shall refer to the manufacturers manual specifications for type of cooling system using the model numbers provided.*