



**MEMORANDUM
ADDENDUM NO. 2**

Date: April 21, 2021
To: Bidders
From: Robin Morgan
Senior Contract Specialist
Florida's Turnpike Enterprise
Subject: DOT-ITB-21-8022-RM
Replacement of Emergency Standby Generators, Fuel Tanks and Automatic Transfer Switches (ATS)
at various locations along the Florida's Turnpike system – North Region

Bidders and other interested parties are informed that the referenced document is hereby revised changed and supplemented as set forth below:

- Attachment C – Scope of Services and General Requirements - Page 1 of 48.

Please replace the above referenced page in the Complete Bid Package with the attached revised page, dated 4/20/2021.

Failure to file a protest within the time prescribed in Section 120.57(3), Florida Statutes, or failure to post the bond or other security required by law within the time allowed for filing a bond shall constitute a waiver of proceedings under Chapter 120, Florida Statutes.

ATTACHMENT “C”
DETAILED SCOPE OF SERVICES AND GENERAL REQUIREMENTS

Generator/Fuel Tank/Automatic Transfer Switch (ATS) Replacement at Five (5) Sites - North Region

PART 1.00 - GENERAL

1.01 WORK INCLUDED

Site; General Scope of work:

1) Yeehaw Junction Maintenance Communication Tower, Building 5252, SR 91, MP 193.0

- The Vendor shall remove and dispose of the existing standby generator and ATS.
- The Vendor shall furnish and install new indoor Liquid Propane (LP), 20 KW 120/240 volts single phase standby generator.
- The Vendor shall furnish and install new 400 AMP single phase ATS unit.
- The Vendor shall install new propane regulators in accordance with the generator’s factory specifications.
- The Vendor shall remove and dispose of existing five hundred (500) gallon LP tank.
- The Vendor shall install new 1,000-gallon LP above ground tank in accordance with Attachment “D,” Fuel tank Mounting Details & Requirements
- The Vendor shall install new LP line and ground the tank.
- The Vendor shall fill the new 1,000-gallon LP tank with fuel to eighty percent (80%) full.
- There is an existing surge suppression system which is to remain and incorporated as part of the new work.
- There are two (2) existing remote alarms for utility power and generator run that are to be reestablished in the new ATS. Provide the necessary alarm terminations or relays. Proper operation of the remote alarms shall be demonstrated to the Contract Manager prior to final acceptance.

2) Kenansville Communication, Building 5059, SR 91, MP 207.0

- The Vendor shall remove and dispose of the existing standby generator and ATS.
- The Vendor shall furnish and install new indoor Liquid Propane (LP), 20 KW 120/240 volts single phase standby generator.
- The Vendor shall furnish and install new 150 AMP single phase ATS unit.
- The Vendor shall install new propane regulators in accordance with the generator’s factory specifications.
- The Vendor shall remove and dispose of existing 500-gallon LP tank.
- The Vendor shall install new 1,000-gallon LP above ground tank in accordance with Attachment “D,” Fuel tank Mounting Details & Requirements.