



STATE OF FLORIDA

DIVISION OF EMERGENCY MANAGEMENT

RON DESANTIS
Governor

KEVIN GUTHRIE
Director

DATE: Tuesday, June 22, 2021
SOLICITATION NUMBER: RFP-DEM-20-21-013
SOLICITATION TITLE: Emergency Fuels
REPLY OPENING: Wednesday, July 7, 2021
ADDENDA NUMBER: 1

This addendum serves as notice of amended pages from the original Request for Proposal (RFP) document.

Remove: Page 3, Attachment A – Scope of Work.

Insert: Attached page 3 Page 3, Attachment A – Scope of Work. (Changes in **red**.)

Please download Attachment B – Price Proposal V2.

All other terms and conditions of the RFP remain unchanged.

FAILURE TO FILE A PROTEST WITHIN THE TIME PRESCRIBED IN FLORIDA STATUTE 120.57(3) OR FAILURE TO FILE A BOND OR OTHER SECURITY WITHIN THE TIME ALLOWED FOR FILING A BOND SHALL CONSTITUTE A WAIVER OF PROCEEDINGS UNDER CHAPTER 120 FLORIDA STATUTES.

Description	Fuel Tank Size (in gallons)
Transport Tanker Trailer Truck	Minimum 8,500
Mobile Fueling Station	Minimum 8,000
High Water Vehicle (All-terrain vehicle capable of fording water 48 inches)	300 – 999
High Water Vehicle (All-terrain vehicle capable of fording water 48 inches)	1,000 – 1,999
High Water Vehicle (All-terrain vehicle capable of fording water 48 inches)	Minimum 2,000

Note: When calculating number of resources, Vendors should include all Vendor owned and sub-contractor owned resources. All fueling points must have meter registers.

B. Resources Not Requiring USDOT Company Snapshot

Vendors must provide the following resources:

Description	Fuel Tank Size (in gallons)
Aviation Fuel Truck	Minimum 2,000
Mini-Mobile Fueling Station	500 – 2,000
Portable Fuel Storage Tank	300 – 4,999
Portable Fuel Storage Tank	Minimum 5,000
Single-Double Wall Frac Tank	16,000 – 21,999
Single-Double Wall Frac Tank	Minimum 22,000
Fuel Pump for Portable Fuel Tanks with Hose and Nozzle	N/A
Portable Gas Operated Transfer Pump	N/A
Delivery Truck for Portable Fuel Tanks	N/A
Portable Spill Berm	N/A

Note: All fuel storage tanks shall be movable, above ground, double walled and come with pump, gauge for inventory level purposes, hose and nozzle for dispensing fuel. Tanks shall meet National Fire Protection Association (NFPA) Code 30. Proof of compliance may be requested. All fueling points must have meter registers.

C. Personnel

Vendors must provide the following personnel:

Title	Description
Logistics Coordinator	See Section 2.5.
Driver / Operator	To operate mobile resources. Costs for Driver / Operator will be included in the rental rate for the mobile resources.
Service Technician	Technician to setup, install and maintain resources.
Fuel Attendant	To operate fuel depots or fueling stations

Note: Rate(s) for personnel must be all inclusive of travel, lodging and per diem.